



Merced College

3600 M Street Merced, CA 95348-2898

Chuck Hergenraeder

Purchasing Manager

Phone: 209-384-6300

Fax: 209-384-6310

Email: charles.hergenraeder@mccd.edu

BID/RFP ADDENDUM

DATE: 6/8/17

BID/RFP No: 2017-09

BID/RFP TITLE: ELECTRICAL POWERLOOP PROJECT

ADDENDUM 1

This addendum contains clarification and additional information, which modifies the conditions of the above referenced BID/RFP as follows:

1. Replace color cement squares with same Red Color
2. Restore landscape on phase one
3. Please provide a separate cost to replace entire sections of cement for areas affected by trenching
4. Remove and replace skateboard rack as part of phase one
5. There is no spare conduit between transformers T7 and T8. Contractor shall remove existing conductors from existing conduit and install new conductors in same existing conduit.
6. The conduit routing shown on the electrical drawings and discussed and identified during the mandatory site walk shall take precedence over the routing shown on the architectural drawings.

SPECIAL NOTE:

It is the responsibility of each Bidder to acknowledge all addenda by signing below and submitting a copy of each addendum with their respective bid.

I HAVE READ AND UNDERSTAND THESE MODIFICATIONS TO THE ABOVE BID: _____

All other bidding contract and construction drawing documents, stipulations, dated and times remain unchanged, in full effect and by reference become a part of this addendum.