



Merced College

3600 M Street Merced, CA 95348-2898

Purchasing Manager
Chuck Hergenraeder
Phone: 209-384-6301
Fax: 209-384-6310

BID/RFP ADDENDUM

DATE: 5/03/17

BID/RFP No: 2017-08

BID/RFP TITLE: Art & ITS Roofing

ADDENDUM 1

This addendum contains clarification and additional information, which modifies the conditions of the above referenced BID/RFP as follows:

1. **BUILDING PREPARATION AND AIR QUALITY**
 - A. Indoor Air Quality: Prior to start of work, request District turn off all HVAC equipment. Completely cover and seal all air intakes to interior of building to prevent any dirt, dust, contamination, water intrusion, odor and other air borne contaminants from entering interiors. Maintain fully in place until all work is complete and roof has been cleaned.
 - B. HVAC Equipment Purge: After work has been completed, and roof and equipment have been fully cleaned, remove covers and seals from equipment. District will then change filters and restart equipment. Coordinate restart with District.
2. Section 01 11 00 - Summary of Work, 1.3, D. - Add to the scope of work, install WhiteKnight Metal primer to all metal flashing's including screen fence pans, pipe penetrations, duct work joints, etc prior to application of the White Knight Plus.
3. Section 01 11 00 - Summary of Work, 1.3, D. - Add to the scope of work, install WhiteKnight Metal primer to all previously coated areas after cleaning and preparation. Lightly sand the existing coated areas prior to application of the primer.
4. Section 01 11 00 - Summary of Work, 1.3, D, 7

Modify the scope of work to read "At all ponding areas, waterways, and areas previously coated install one layer of Ultimat reinforcement into the wet coating without overworking the material. Allow to dry a minimum of 24 hours prior to application of the top coat.

SPECIAL NOTE:

It is the responsibility of each Bidder to acknowledge all addenda by signing below and submitting a copy of each addendum with their respective bid.

I HAVE READ AND UNDERSTAND THESE MODIFICATIONS TO THE ABOVE BID: _____

All other bidding contract and construction drawing documents, stipulations, dated and times remain unchanged, in full effect and by reference become a part of this addendum.